

RESOLUTION 15-18

2014 COMPLIANCE MAINTENANCE ANNUAL REPORT

WHEREAS, the Compliance Maintenance Annual Report describes wastewater management activities, physical conditions and performance of the treatment works during the previous calendar year; and

WHEREAS, State Statutes Chapter 283, Department of Natural Resources Administrative Code NR 208 requires the Common Council adopt a resolution accepting the Compliance Maintenance Report prepared by the Water and Sewer Department; and

WHEREAS, a copy of the report is attached.

NOW, THEREFORE, BE IT RESOLVED, by the Common Council of the City of Platteville that the attached report is hereby approved.

Adopted this 28th day of July, 2015.

BY ORDER OF THE COMMON COUNCIL
CITY OF PLATTEVILLE, WISCONSIN



Eileen Nickels, Council President

ATTEST:



Jan Martin, City Clerk

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:
7/13/2015 **2014**

Influent Flow and Loading

Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Outfall No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	0.6635	x	310	x	8.34	=	1,717
February	0.7943	x	357	x	8.34	=	2,366
March	0.8710	x	247	x	8.34	=	1,797
April	0.9315	x	274	x	8.34	=	2,125
May	0.7266	x	294	x	8.34	=	1,782
June	0.8187	x	248	x	8.34	=	1,692
July	0.6563	x	275	x	8.34	=	1,504
August	0.6337	x	279	x	8.34	=	1,477
September	0.7800	x	303	x	8.34	=	1,968
October	0.7551	x	355	x	8.34	=	2,234
November	0.7217	x	354	x	8.34	=	2,130
December	0.6643	x	371	x	8.34	=	2,056

2. Maximum Month Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	2.05	x	90	=	1.845
		x	100	=	2.05
Design (C)BOD, lbs/day	3230	x	90	=	2907
		x	100	=	3230

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

☒ Yes

Enter last calibration date (MM/DD/YYYY) 05/27/2014

☐ No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

☒ Yes

☐ No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

☐ Yes

☒ No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

☒ Yes

☒ Yes

☐ Yes

☐ No

☐ No

☒ No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

☒ Yes

10,900

gallons

☐ No

Holding Tanks

☒ Yes

543,625

gallons

☐ No

Grease Traps

☐ Yes

gallons

☒ No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

Was not affected.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

☐ Yes

☒ No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

☐ Yes

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:
7/13/2015 2014

<ul style="list-style-type: none">• No <p>If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.</p> <div></div>	
---	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	4	1	0	0
February	30	27	3	1	0	0
March	30	27	2	1	0	0
April	30	27	1	1	0	0
May	15	13.5	0	1	0	0
June	15	13.5	0	1	0	0
July	15	13.5	0	1	0	0
August	15	13.5	0	1	0	0
September	15	13.5	0	1	0	0
October	15	13.5	0	1	0	0
November	30	27	1	1	0	0
December	30	27	0	1	0	0

* Equals limit if limit is ≤ 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

☒ Yes

Enter last calibration date (MM/DD/YYYY)

05/27/2014

☐ No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

None

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

☐ Yes

☒ No

If Yes, please explain:

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?

☐ Yes

☒ No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?

☐ Yes

☐ No

☒ N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	4	1	0	0
February	30	27	3	1	0	0
March	30	27	2	1	0	0
April	30	27	2	1	0	0
May	15	13.5	12	1	0	0
June	15	13.5	2	1	0	0
July	15	13.5	1	1	0	0
August	15	13.5	1	1	0	0
September	15	13.5	1	1	0	0
October	15	13.5	2	1	0	0
November	30	27	2	1	0	0
December	30	27	2	1	0	0

* Equals limit if limit is ≤ 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:	7	3	
Exceedances	0	0	
Points	0	0	
Total Number of Points		0	

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Effluent Quality and Plant Performance (Ammonia - NH3)

Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for NH3

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceed ance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceed ance
January	4.6		1.727272727	0					
February	4.6		.0505	0					
March	4.6		.024545455	0					
April	2.9		.066363636	0					
May	1.5		.023809524	0					
June	1.5		.040909091	0					
July	1.5		.017826087	0					
August	1.5		.076363636	0					
September	1.5		.086818182	0					
October	4.6		.142272727	0					
November	4.6		.055238095	0					
December	4.6		.036956522	0					

Points per each exceedance of Monthly average: 10

Exceedances, Monthly: 0

Points: 0

Points per each exceedance of weekly average (when there is no monthly average): 2.5

Exceedances, Weekly: 0

Points: 0

Total Number of Points 0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to detect exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to detect exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1	0.3	1	0
February	1	0.3	1	0
March	1	0.4	1	0
April	1	0.4	1	0
May	1	0.5	1	0
June	1	0.5	1	0
July	1	0.5	1	0
August	1	0.4	1	0
September	1	0.6	1	0
October	1	0.6	1	0
November	1	0.4	1	0
December	1	0.6	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				0
Total Number of Points				0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Last Updated: 7/13/2015 Reporting For: **2014**

[illegible]

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Outfall No. 003 - CAKE SLUDGE

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75				7.84										0	0
Cadmium		39	85				9.92										0	0
Copper		1500	4300				634										0	0
Lead		300	840				46.3										0	0
Mercury		17	57				.793										0	0
Molybdenum	60		75				8.74									0		0
Nickel	336		420				27.1									0		0
Selenium	80		100				7.17									0		0
Zinc		2800	7500				1280										0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

- 0 (0 Points)
- 1-2 (10 Points)
- > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
- No (10 points)

- N/A - Did not exceed limits or no HQ limit applies (0 points)
- N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
- 1 (10 Points)
- > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
- No (0 Points)

3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?

4. Pathogen Control (per outfall):

4.1 Verify the following information. If any information is incorrect, Contact Us.

Outfall Number:	003
Biosolids Class:	B
Bacteria Type and Limit:	
Sample Dates:	01/01/2014 - 12/31/2014
Density:	
Sample Concentration Amount:	
Requirement Met:	Yes
Land Applied:	Yes
Process:	ANAER
Process Description:	Primary digester 477,000 gals. Temp 96 degrees PH 7.1 Gas mixing and recirculation. Secondary Digester 189,350, Gas storage and Sludge sedimentation. Gas production both digesters

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:
7/13/2015 **2014**

Outfall Number:	003
Biosolids Class:	B
Bacteria Type and Limit:	
Sample Dates:	01/01/2014 - 12/31/2014
Density:	
Sample Concentration Amount:	
Requirement Met:	Yes
Land Applied:	Yes
Process:	ANAER
Process Description:	Primary digester 477,000 gals. Temp 96 degrees PH 7.1 Gas mixing and recirculation. Secondary Digester 189,350 gals. Gas storage and Sludge sedimentation. Gas production both digester 18,00 to 20,00 cubic ft. per day.

Outfall Number:	003
Biosolids Class:	B
Bacteria Type and Limit:	
Sample Dates:	07/01/2014 - 12/31/2014
Density:	
Sample Concentration Amount:	
Requirement Met:	Yes
Land Applied:	Yes
Process:	ANAER
Process Description:	Primary digester 477,000 gals. Temp 96 degrees PH 7.1. Gas mixing and recirculation. Secondary Digester 189,350 gas storage and sludge sedimentation. Gas production both digesters 18,000 to 20,000 cu ft. per day.

Outfall Number:	003
Biosolids Class:	B
Bacteria Type and Limit:	
Sample Dates:	07/01/2014 - 12/31/2014
Density:	
Sample Concentration Amount:	
Requirement Met:	Yes
Land Applied:	Yes
Process:	ANAER
Process Description:	Primary digester 477,000 gals. Temp 96 degrees PH 7.1. Gas mixing and recirculation. Secondary Digester 189,350 Gas storage and Sludge sedimentation. Gas production both digesters 18,000 to 20,000 Cu ft/day

- 4.2 If exceeded Class B limit or did not meet the process criteria at the time of land application.
- 4.2.1 Was the limit exceeded or the process criteria not met at the time of land application?
- ☐ Yes (40 Points)
 - ☒ No

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

If yes, what action was taken?

0

5. Vector Attraction Reduction (per outfall):

5.1 Verify the following information. If any of the information is incorrect, Contact Us.

Outfall Number:	003
Method Date:	05/02/2014
Option Used To Satisfy Requirement:	VSR
Requirement Met:	Yes
Land Applied:	Yes
Limit (if applicable):	38
Results (if applicable):	69.10

Outfall Number:	003
Method Date:	05/02/2014
Option Used To Satisfy Requirement:	VSR
Requirement Met:	Yes
Land Applied:	Yes
Limit (if applicable):	38
Results (if applicable):	69.10

Outfall Number:	003
Method Date:	05/02/2014
Option Used To Satisfy Requirement:	VSR
Requirement Met:	Yes
Land Applied:	Yes
Limit (if applicable):	38
Results (if applicable):	69.10

Outfall Number:	003
Method Date:	05/02/2014
Option Used To Satisfy Requirement:	VSR
Requirement Met:	Yes
Land Applied:	Yes
Limit (if applicable):	38
Results (if applicable):	69.10

5.2 Was the limit exceeded or the process criteria not met at the time of land application?

○ Yes (40 Points)

● No

If yes, what action was taken?

6. Biosolids Storage

6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?

● >= 180 days (0 Points)

○ 150 - 179 days (10 Points)

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

<ul style="list-style-type: none">o 120 - 149 days (20 Points)o 90 - 119 days (30 Points)o < 90 days (40 Points)o N/A (0 Points) <p>6.2 If you checked N/A above, explain why.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0
<p>7. Issues</p> <p>7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Staffing and Preventative Maintenance (All Treatment Plants)

1. Plant Staffing

1.1 Was your wastewater treatment plant adequately staffed last year?

☒ Yes

☐ No

If No, please explain:

Could use more help/staff for:

1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?

☒ Yes

☐ No

If No, please explain:

2. Preventative Maintenance

2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?

☒ Yes (Continue with question 2)

☐ No (40 points)

If No, please explain, then go to question 3:

2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?

☒ Yes

☐ No (10 points)

2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?

☒ Yes

☐ Paper file system

☐ Computer system

☒ Both paper and computer system

☐ No (10 points)

0

3. O&M Manual

3.1 Does your plant have a detailed O&M Manual that can be used as a reference when needed?

☒ Yes

☐ No

4. Overall Maintenance /Repairs

4.1 Rate the overall maintenance of your wastewater plant.

☒ Excellent

☐ Very good

☐ Good

☐ Fair

☐ Poor

Describe your rating:

We have a highly trained and competent staff.

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Operator Certification and Education

1. Operator-In-Charge 1.1 Did you have a designated operator-in-charge during the report year? ● Yes (0 points) ○ No (20 points) Name: DENNIS MOEN Certification No: 01879	0
2. Certification Requirements 2.1 In accordance with Chapter NR 114.08 and 114.09, Wisconsin Administrative Code, what grade and subclass(es) were required for the operator-in-charge to operate the wastewater treatment plant and what grade and subclass(es) were held by the operator-in-charge? Required: 4 - ABCEFGHIJ; A - PRIMARY SETTLING; B - TRICKLING FILTER/RBC; C - ACTIVATED SLUDGE; E - DISINFECTION; F - ANAEROBIC DIGESTION; G - MECHANICAL SLUDGE; H - FILTRATION; I - PHOSPHORUS REMOVAL; J - LABORATORY Held: 4 - ABCEFGHIJ; 1 - D; 4 - A=PRIMARY SETTLING GRADE 4; B=TRICKLING FILTER/RBC GRADE 4; C=ACTIVATED SLUDGE GRADE 4; E=DISINFECTION GRADE 4; F=ANAEROBIC DIGESTION GRADE 4; G=MECHANICAL SLUDGE GRADE 4; H=FILTRATION GRADE 4; I=PHOSPHORUS REMOVAL GRADE 4; J=LABORATORY GRADE 4; 1 - D=PONDS/AERATED LAGOONS GRADE 1 2.2 Was the operator-in-charge certified at the appropriate level to operate this plant? ● Yes (0 points) ○ No (20 points)	0
3. Succession Planning 3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)? <input checked="" type="checkbox"/> One or more additional certified operators on staff <input type="checkbox"/> An arrangement with another certified operator <input type="checkbox"/> An arrangement with another community with a certified operator <input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year <input type="checkbox"/> A consultant to serve as your certified operator <input type="checkbox"/> None of the above (20 points) If "None of the above" is selected, please explain:	0
4. Continuing Education Credits 4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates? Grades T, 1, and 2: ○ Averaging 6 or more CECs per year. ○ Averaging less than 6 CECs per year. Grades 3 and 4: ● Averaging 8 or more CECs per year. ○ Averaging less than 8 CECs per year.	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:
7/13/2015 **2014**

Financial Management

Provider of Financial Information

Name: Valerie Martin

Telephone: (608) 348-9741

(XXX) XXX-XXXX

E-Mail Address
(optional): martin@platteville.org

2. Treatment Works Operating Revenues

2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?

☒ Yes (0 points)

☐ No (40 points)

If No, please explain:

2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?

Year: 2013

☒ 0-2 years ago (0 points)

☐ 3 or more years ago (20 points)

☐ N/A (private facility)

2.3 Did you have a special account (e.g., CWF required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?

☒ Yes (0 points)

☐ No (40 points)

0

REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]

3. Equipment Replacement Funds

3.1 When was the Equipment Replacement Fund last reviewed and/or revised?

Year: 2014

☒ 1-2 years ago (0 points)

☐ 3 or more years ago (20 points)

☐ N/A

If N/A, please explain:

3.2 Equipment Replacement Fund Activity

3.2.1 Ending Balance Reported on Last Year's CMAR

\$ 1,423,664.45

3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)

\$ 0.00

3.2.3 Adjusted January 1st Beginning Balance

\$ 1,423,664.45

3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)

+ \$ 250,000.00

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)

- \$ 142,906.71

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 1,530,757.74

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

Filter Building Valve Replacement, SCADA ,#2 boiler rebuild

3.3 What amount should be in your Replacement Fund? \$ 284,586.98

Please note: If you had a CWFP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the HELP link under Info in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

☒ Yes

☐ No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

☒ Yes - If Yes, please provide major project information, if not already listed below.

☐ No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	rehab. primary clarifier	25000	2013
2	Sludge Truck	120000	2013
3	Intermediate Clarifier rehab	100,000	2016
4	Sludge boiler rebuild	25000	2015
5	WWTP Valve replacements	20,000	2015
6	Centrifuge Rehab	10000	2015
7	WWTP Main Building Boiler	25000	2016
8	Non-potable water systems control	10000	2017

5. Financial Management General Comments

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Sanitary Sewer Collection Systems

CMOM Program

1.1 Do you have a Capacity, Management, Operation & Maintenance (CMOM) requirement in your WPDES permit?

- Yes
- No

1.2 Did you have a documented (written records/files, computer files, video tapes, etc.) sanitary sewer collection system operation & maintenance (O&M) or CMOM program last calendar year?

- Yes (Continue with question 1)
- No (30 points) (Go to question 2)

1.3 Check the elements listed below that are included in your O&M or CMOM program.

☒ Goals

Describe the specific goals you have for your collection system:

I/I reduction, system cleaning/televising, collection system infrastructure.

☒ Organization

Do you have the following written organizational elements (check only those that apply)?

- ☒ Ownership and governing body description
- ☒ Organizational chart
- ☒ Personnel and position descriptions
- ☒ Internal communication procedures
- ☒ Public information and education program

☒ Legal Authority

Do you have the legal authority for the following (check only those that apply)?

☒ Sewer use ordinance Last Revised Date (MM/DD/YYYY) 05/21/1985

- ☐ Pretreatment/industrial control Programs
- ☒ Fat, oil and grease control
- ☐ Illicit discharges (commercial, industrial)
- ☒ Private property clear water (sump pumps, roof or foundation drains, etc.)
- ☒ Private lateral inspections/repairs
- ☐ Service and management agreements

☒ Maintenance Activities (provide details in question 2)

☒ Design and Performance Provisions

How do you ensure that your sewer system is designed and constructed properly?

- ☒ State plumbing code
- ☒ DNR NR 110 standards
- ☒ Local municipal code requirements
- ☒ Construction, inspection, and testing
- ☒ Others:

Platteville standard specifications.

☒ Overflow Emergency Response Plan:

Does your emergency response capability include (check only those that apply)?

- ☒ Alarm system and routine testing
- ☒ Emergency equipment
- ☒ Emergency procedures
- ☒ Communications/notifications (DNR, internal, public, media, etc.)

☒ Capacity Assurance:

How well do you know your sewer system? Do you have the following?

- ☒ Current and up-to-date sewer map
- ☒ Sewer system plans and specifications

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

- ☒ Manhole location map
- ☒ Lift station pump and wet well capacity information
- ☒ Lift station O&M manuals

Within your sewer system have you identified the following?

- ☒ Areas with flat sewers
- ☐ Areas with surcharging
- ☒ Areas with bottlenecks or constrictions
- ☒ Areas with chronic basement backups or SSOs
- ☒ Areas with excess debris, solids, or grease accumulation
- ☒ Areas with heavy root growth
- ☒ Areas with excessive infiltration/inflow (I/I)
- ☒ Sewers with severe defects that affect flow capacity
- ☒ Adequacy of capacity for new connections
- ☒ Lift station capacity and/or pumping problems
- ☒ Annual Self-Auditing of your O&M/CMOM Program to ensure above components are being implemented, evaluated, and re-prioritized as needed
- ☒ Special Studies Last Year (check only those that apply):
 - ☐ Infiltration/Inflow (I/I) Analysis
 - ☐ Sewer System Evaluation Survey (SSES)
 - ☐ Sewer Evaluation and Capacity Management Plan (SECAP)
 - ☒ Lift Station Evaluation Report
 - ☐ Others:

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="19"/>	% of system/year
Root removal	<input type="text" value="1"/>	% of system/year
Flow monitoring	<input type="text" value="0"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="20"/>	% of system/year
Manhole inspections	<input type="text" value="50"/>	% of system/year
Lift station O&M	<input type="text" value="52"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="0"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="10"/>	% of system/year
Private sewer I/I removal	<input type="text" value="0"/>	% of private services

Please include additional comments about your sanitary sewer collection system below:

Private I&I 2%

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

24.8	Total actual amount of precipitation last year in inches
36	Annual average precipitation (for your location)
52	Miles of sanitary sewer
4	Number of lift stations
0	Number of lift station failures
0	Number of sewer pipe failures
0	Number of basement backup occurrences
0	Number of complaints
.752	Average daily flow in MGD (if available)
.932	Peak monthly flow in MGD (if available)
	Peak hourly flow in MGD (if available)
3.2 Performance ratios for the past year:	
0.00	Lift station failures (failures/year)
0.00	Sewer pipe failures (pipe failures/sewer mile/yr)
0.02	Sanitary sewer overflows (number/sewer mile/yr)
0.00	Basement backups (number/sewer mile)
0.00	Complaints (number/sewer mile)
1.2	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
0.0	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

.. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OFERFLOWS REPORTED **				
	Date	Location	Cause	Estimated Volume (MG)
0	6/16/2014 12:00:00 AM - 9/11/2014 12:00:00 AM	North side of Business 151, 500 feet west of Highway 80/81. Leak occurred 30 feet up hill side.	Broken Sewer, Broken Sewer	0.0002 - 0.0005

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

What actions were taken, or are underway, to reduce or eliminate SSO or TFO occurences in the future?

pipe was damaged from tornado and pipe is repaired

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

☐ Yes

☒ No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

☐ Yes

☒ No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

less I/I directly related to sewer main replacement

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

5.4 What is being done to address infiltration/inflow in your collection system?

continuous monitoring for bad areas

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:
7/13/2015 2014

Grading Summary

VPDES No: 0020435

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	148
GRADE POINT AVERAGE (GPA) = 4				

Notes:

A = Voluntary Range (Response Optional)

B = Voluntary Range (Response Optional)

C = Recommendation Range (Response Required)

D = Action Range (Response Required)

F = Action Range (Response Required)

Compliance Maintenance Annual Report

Platteville Wastewater Treatment Facility

Last Updated: Reporting For:

7/13/2015

2014

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Date of Resolution or
Action Taken:

Resolution Number:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F. Regardless of grade, required for Collection Systems if SSOs were reported):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS (Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 4